

ATTACHMENT 5A

Division of Environmental Health Referral Comments

01/09/2023	01/13/2023	JWHITTLESEY	Approved with Conditions	
				<p>Onsite employee occupancy and processing activities must be supported by an approved onsite wastewater treatment system (OWTS). Seasonal/outdoor cultivation sites may be supported by portable toilets. Applicant must obtain a permit for, and install, and approved OWTS to support employee housing and processing locations and either install approved OWTS or provide portable toilets to cultivation areas.</p> <p>Agricultural chemicals and pesticides shall be stored a minimum of 100' horizontal distance from any water well. Proposed 12'X8' chemical storage shed as described on Site Plan prepared by Trinity Valley Consulting Engineers dated Dec 2022 must adhere to this setback.</p>
				check spelling