

EXHIBIT A



DEPARTMENT OF PUBLIC WORKS  
COUNTY OF HUMBOLDT

MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579  
AREA CODE 707

ON-LINE  
WEB: CO.HUMBOLDT.CA.US

ADMINISTRATION	445-7491	NATURAL RESOURCES	445-7741
BUSINESS	445-7652	NATURAL RESOURCES PLANNING	267-9540
ENGINEERING	445-7377	PARKS	445-7651
FACILITY MANAGEMENT	445-7493	ROADS	445-7421

CLARK COMPLEX	
HARRIS & H ST., EUREKA	
FAX 445-7388	
LAND USE	445-7205

LAND USE DIVISION INTEROFFICE MEMORANDUM

TO: Cliff Johnson, Supervising Planner

FROM: Ken Freed, Assistant Engineer *KF*

RE: SUBDIVISION REQUIREMENTS - IN THE MATTER OF THE  
APPLICATION OF BRIGHT VIEW HOMES LLC, APN 510-121-026, PLN-  
2023-18247 FMS APPROVAL OF A TENTATIVE MAP, CONSISTING OF 1.6  
ACRES INTO 7 LOTS

DATE: 08/08/2014  
10/08/2015 revised  
12/03/2015 revised by Planning Commission  
09/06/2023 revised by Public Works

*The following requirements and standards are applicable to this project and must be completed to the specifications and satisfaction of the Department of Public Works (Department) before the subdivision map may be filed with the County Recorder. If there has been a substantial change in the project since the last date shown above, an amended report must be obtained and used in lieu of this report. Prior to commencing the improvements indicated below, please contact the Subdivision Inspector at 445-7205 to schedule a pre-construction conference.*

**These recommendations are based on the tentative map prepared by Points West Surveying dated April 2015, and received by Humboldt County Planning Division on June 27, 2023.**

NOTE: All correspondence (letters, memos, faxes, construction drawings, reports, studies, etc.) with this Department must include the Assessor Parcel Number (APN) shown above.

**READ THE ENTIRE REPORT BEFORE COMMENCING WORK ON THE PROJECT**

1.0 MAPPING

1.1 **EXPIRATION OF TENTATIVE MAP:** Applicant is advised to contact the Planning & Building Department to determine the expiration date of the tentative map and what time extension(s), if any, are applicable to the project. Applicant is responsible for the timely filing of time extension requests to the Planning & Building Department.

Applicant is responsible for completing all of the subdivision requirements prior to expiration of the tentative map. Applicant is advised to promptly address all of the subdivision requirements in order to avoid the tentative map expiring prior to completion of the subdivision requirements. Applicants are encouraged to contact a land development professional for advice on developing a realistic schedule for the processing of the project.

- 1.2 **MAP TYPE:** Applicant must cause to be filed a subdivision map showing monumentation of all property corners to the satisfaction of this Department in compliance with Humboldt County Code Section 326-15. Subdivision map checking fees shall be paid in full at the time the subdivision map is submitted for checking. County Recorder fees shall be paid prior to submittal of the map to the County Recorder for filing. The subdivision map must be prepared by a Land Surveyor licensed by the State of California -or- by a Civil Engineer registered by the State of California who is authorized to practice land surveying.

All Department charges associated with this project must be paid in full prior to the subdivision map being submitted to the County Recorder for filing.

Applicant shall submit to this Department four (4) full-size copies of the subdivision map as filed by the County Recorder.

Prior to submitting the subdivision map to the County Surveyor for map check, applicant shall submit the subdivision map to the utility providers to provide input on necessary public utility easements. Copies of the responses from the utility providers shall be included with the first submittal of the subdivision map to the County Surveyor.

- 1.3 **DEPOSIT:** Applicant shall be required to place a security deposit with this Department for inspection and administration fees as per Humboldt County Code Section 326-13 prior to review of the improvement plans, review of the subdivision map, or the construction of improvements, whichever occurs first.

- 1.4 **EASEMENTS:** All easements that encumber or are appurtenant to the subdivision shall be shown graphically on the subdivision map. Those easements that do not have a metes and bounds description shall be noted on the subdivision map and shown as to their approximate location.

- 1.5 **DEDICATIONS:** The following shall be dedicated on the subdivision map, or other document as approved by this Department:

(a) **Railroad Drive (County Road No. 4M020):**

Public Road: Applicant shall cause to be dedicated on the subdivision map to the County of Humboldt an easement for public road purposes lying within 25 feet of the center line of the County road. The applicant is only responsible to cause to be dedicated lands that are included within the boundary of the proposed subdivision.

Sidewalks: Applicant shall cause to be dedicated on the subdivision map to the County of Humboldt a 10 foot wide easement for public sidewalk purposes lying adjacent to the right of way of the County road. The applicant is only responsible to cause to be dedicated lands that are included within the boundary of the proposed subdivision. This easement may overlap a public utility easement.

PUE: Applicant shall cause to be dedicated to the County of Humboldt on the subdivision map a 10 foot wide public utility easement (PUE) adjacent to the right of way for the road or as otherwise approved by this Department. Additional PUEs shall be dedicated in a manner, width, and location approved by this Department.

(b) **Midtown Court (Not County Maintained):**

Access: Applicant shall cause to be dedicated on the subdivision map a non-exclusive easement for ingress, egress, and public utilities for the benefit of the lots within the subdivision in a manner approved by this Department. The easement is variable in width and ranges from 30 to 35 feet in width.

A turn-around area shall be provided at the end of road.

PUE: Applicant shall cause to be dedicated to the County of Humboldt on the subdivision map a 10 foot wide public utility easement (PUE) adjacent to the right of way for the road or as otherwise approved by this Department. Additional PUEs shall be dedicated in a manner, width, and location approved by this Department.

The applicant shall cause to be dedicated to the County of Humboldt a PUE over the entire area of the access easement for the road.

Sidewalks: Applicant shall cause to be dedicated on the subdivision map a non-exclusive 10 foot wide easement for sidewalk purposes lying adjacent to the right of way of the access roads within the subdivision. Said easement shall be for the benefit of the lots within the subdivision and shall be dedicated in manner, width, and location as approved by this Department. This easement may overlap a public utility easement.

(c) **NEIGHBORHOOD BOX UNIT (NBU) MAILBOXES:** Prior to submittal of the subdivision map, provide a sign-off from the post office on the location of the neighborhood box unit. Applicant shall cause to be dedicated on the subdivision map additional sidewalk easements as necessary to accommodate the NBU.

**1.6 PRIVATE ROAD:** Pursuant to County Code Section 323-2(c)(3), the subdivision map shall show the lanes clearly labeled "Non-County Maintained Lane" or "Non-County Maintained Road".

Pursuant to County Code Section 323-2(c)(5), the following note shall appear on the map or instrument of waiver, which shall read substantially as follows:

"If the private lane or lanes shown on this plan of subdivision, or any part thereof, are to be accepted by the County for the benefit of the lot owners on such lane rather than the benefits of the County generally, such private lane or lanes or parts thereof shall first be improved at the sole cost of the affected lot owner or owners, so as to comply with the specification as contained in the then applicable subdivision regulations relating to public streets."

[County Code Section 323-2 appears after Section 324-1 in County Code]

**2.0 IMPROVEMENTS**

- 2.1 **CONSTRUCTION PLANS:** Construction plans shall be submitted for any required road, drainage, landscaping, and pedestrian improvements. Construction plans must be prepared by a Civil Engineer registered by the State of California. Construction plans shall be on a sheet size of 22" x 34", unless approved otherwise by this Department. Construction of the improvements shall not commence until authorized by this Department. This Department will require the submittal of 2 full size (22" x 34") set and 1 reduced (11" x 17") set of the approved construction plans prior to start of work.

The construction plans shall show the location of all proposed new utilities and any existing utilities within 10 feet of the improvements. The plans shall be signed as approved by the local fire response agency and public utility companies having any facilities within the subdivision prior to construction authorization by this Department.

Construction plans shall be tied into elevation datum approved by this Department. Projects located within McKinleyville Community Services District (MCSD) area shall be tied to MCSD elevation datum unless waived by this Department.

Unless otherwise waived by this Department, record drawing ("As-Built") plans shall be submitted for any road, drainage, landscaping, and pedestrian improvements that are constructed as part of this project. Record drawing plans must be prepared by a Civil Engineer registered by the State of California. Once approved by this Department, one (1) set of "wet stamped" record drawings on 22" x 34" mylar sheets shall be filed with this Department.

- 2.2 **CONSTRUCTION PERIOD:** Construction of improvements for this project will not be allowed to occur between October 15 and April 15 without permission of this Department.
- 2.3 **ADA FACILITIES:** All pedestrian facilities shall be ADA compliant. This includes, but is not limited to, providing curb ramps at intersections and sidewalks behind driveway aprons (or ADA compliant driveway aprons).

Fire hydrants, neighborhood box units for mail, utility poles (including down guys), street lights, or other obstructions will not be allowed in sidewalks unless approved by this Department.

Applicant shall replace/retrofit to meet current standards any non-ADA compliant pedestrian improvements within the public right of way (or access easements that the subject property has a legal right to use) contiguous to the project.

The construction of curb ramps also requires the upgrade of non-ADA compliant companion curb ramps that may be off-site.

- 2.4 **ROAD NAMES:** The access road(s)/street(s) shall be named as approved by the Planning & Building Department - Planning Division.
- 2.5 **TRAFFIC CONTROL DEVICES:** Street name and traffic control devices may need to be placed as required and approved by this Department.

A stop sign will be required on Midtown Court at its intersection with Railroad Drive.

In addition, pursuant to County Code Section 323-2(c)(4), non-county maintained roads shall be posted with a sign of at least 2 square feet in size containing substantially the following words in 2" high black letters on a yellow background: "Not a County Maintained Road" or "Not a County Maintained Street". The sign shall be approved by the Department prior to installation.


2.6 **ACCESS ROADS:** The surface of the access road(s) shall conform to the *Structural Section* requirements within this document. The access road(s) serving the subdivision shall be constructed to the satisfaction of this Department as follows:

- (a) The intersection of Midtown Court and the Railroad Drive (County Road No. 4M020) shall be constructed in conformance with the standards for a private road intersection as illustrated in Caltrans standards; and shall have 20 foot radius curb returns due to the narrow lanes on Midtown Court. The access opening must conform to Humboldt County Code Section 341 regarding visibility.


Curb ramps shall be provided at the intersection of Midtown Court and Railroad Drive.

- (b) ~~**MIDTOWN COURT (Not County Maintained):** Midtown Court shall be constructed having a typical section comprised of two 10 foot wide travel lanes, an eight foot wide parking lane, a PCC Caltrans Type A1-6 curb [or APWA A3-150(6) curb], a 5 foot wide landscape strip (4.5 feet useable); and a 5 foot wide PCC sidewalk. The parking lane, landscape strip and sidewalk shall be located on the east side of the road. The sidewalk shall be constructed along the east side of the road from as shown on the tentative map ends at Lot 2; the sidewalk shall be extended to the southwest to connect to the Midtown Trail. The turn around and west side of the road shall be signed/stripped for "no parking".~~

~~The road is proposed to be cross sloped to the west to drain to the storm water detention basin. A Caltrans Type A2-6 PCC curb and gutter may be needed along the west side of the road from Railroad Drive (County Road No. 4M020) to the storm water detention basin.~~



~~*Above: Typical Section for Midtown Court*~~




*Above: location of sidewalk improvements*


~~A turnaround area as approved by this Department shall be constructed at the end of the access road serving the subdivision. It shall have the same structural section as the roadway serving the parcels/lots. If the turnaround area does not include a parking lane, then the turnaround area shall be signed/striped for "no parking".~~

~~A minimum of one street tree shall be planted in front of each lot, spaced approximately 50 feet apart. It is noted that it may be impractical to plant a street tree in front of lots 1, 2 and 3 due to narrow lot width and utility conflicts at the turn around. It is noted that Lot 7 has sufficient frontage for approximately 4 street trees. [12/03/2015 revised by Planning Commission.]~~

**(b) MIDTOWN COURT (Not County Maintained):** Midtown Court shall be constructed having a typical section comprised of two 10 foot wide travel lanes. The road shall be widened to be 26 feet in width for the first 50 feet; then taper down to 20 feet. The road (including the turn around area) shall be signed/striped for "no parking". The road is proposed to have a tilt section.


The road is proposed to be cross sloped to the west to drain to the storm water detention basin. A Caltrans Type A2-6 PCC curb and gutter may be needed along the west side of the road from Railroad Drive (County Road No. 4M020) to the storm water detention basin.





*Above: Typical sections for Midtown Court (Alternate)*

The applicant's agent has advised the Department that since no parking is to be provided, the A1 curb shown on the uphill side of the road may not be necessary.



*Above: diagram showing the 26' wide road at the intersection of Railroad Drive*

[revised by the Planning Commission on 12/03/2015]

- (c) Nothing is intended to prevent the applicant from constructing the improvements to a greater standard.
- (d) Nothing is intended to prevent this Department from approving alternate typical sections, structural sections, drainage systems, and road geometrics based upon sound engineering principals as contained in, but not limited to, the Humboldt County Roadway Design Manual, Caltrans Highway Design Manual, Caltrans Local Programs Manual, Caltrans Traffic Manual, California Manual on Uniform Traffic Control Devices (MUTCD), and AASHTO's A Policy of Geometric Design of Highways and Streets (AKA "The Green Book"). Engineering must not be in conflict with Humboldt County Code or County adopted guidelines and policies.
- (e) Applicant shall remove and replace any public curb, gutter, sidewalk, flowline drain, or pavement found by this Department to be broken, uplifted, or damaged that fronts or is within the subdivision.
- (f) All road intersections shall conform to Humboldt County Code Section 341 regarding visibility.

- 2.7 **DRIVEWAYS:** All access openings (existing and proposed) shall conform to Humboldt County Code Section 341 regarding visibility. All access openings (existing and proposed) shall intersect the road at a 90° angle, unless otherwise approved by this Department.

All access openings (existing and proposed) shall be paved with hot mix ("asphalt") for the width of the driveway and a distance of 25 feet from the edge of the road.

That portion of a structure used for the parking of vehicles must be setback a minimum of 20 feet from easements created as a condition of tentative map approval for the purpose of moving automotive vehicles, bicycles, pedestrians, or animals. A development plan must be created as a condition of approval of the tentative map. The development plan must note this minimum setback condition and indicate graphically the location of the setback line on the lots.

All access openings (existing and proposed) shall be shown on the improvement plans.

- 2.8 **STRUCTURAL SECTION:** The access road(s) shall be constructed to a structural section recommended in the soils report and as approved by this Department.

- (a) **For paved road surfaces,** the structural section shall include a minimum of 0.2 foot of Caltrans Type B hot mix ("asphalt") over 0.67 foot of Caltrans Class 2 aggregate base. If required by this Department, the structural section of all roads shall be determined by Caltrans R-Value method using a Traffic Index (T.I.) approved by this Department. Based upon soil conditions, this Department may also require a geotextile fabric to be placed on top of the sub grade.

When widening hot mix ("asphalt") roads, the widened road shall be paved with hot mix. A sawcut is required to ensure a uniform joint between the existing and new pavements. The location of the sawcut shall be approved by this Department based upon the condition of the existing road surface.

- (b) Access roads and driveways may include decorative accent treatments such as, but not limited to, stamped concrete or decorative brick pavers. Decorative accent treatments must provide appropriate traction for pedestrians, bicycles, and vehicles. **Decorative access treatments are not permitted within the public right of way,** unless approved in writing by this Department.

- 2.9 **UNKNOWN IMPROVEMENTS:** Other on-site and/or off-site improvements may be required which cannot be determined from the tentative map and/or preliminary improvement plans at this time. These improvements will be determined after more complete improvement plans and profiles have been submitted to the County for review.

- 2.10 **UTILITIES:** The proposed improvements may require the undergrounding or relocation of existing facilities at the expense of the applicant. Undergrounding of existing facilities, relocation of existing facilities, or construction of new facilities shall be completed prior to constructing the structural section for the roadway.

If any utilities are required to be installed as a condition of tentative map, the utility work shall be completed prior to constructing the structural section for the road. All laterals shall be extended onto each lot and marked in a manner that they will be easily located at the time



of individual hookups. A letter of completion of all work from each involved utility company shall be submitted prior to constructing the roadway structural section. Any utilities that need to be relocated shall be done solely at the subdivider's expense.

Applicant shall remove any abandoned utilities (natural gas, electrical, cable tv, etc.) within the public right of way fronting the subdivision or within the subdivision as directed by this Department.

- 2.11 **PERMITS:** An encroachment permit is required to be obtained prior to construction from this Department for all work within the right of way of a County maintained road.
- 2.12 **NEIGHBORHOOD BOX UNIT (NBU) MAILBOXES.** When clustered mailboxes (neighborhood box units) are required by the Post Office, applicant shall obtain approval for the location of the mailbox unit from the Post Master. The pad for the mailbox unit shall be constructed as part of the subdivision and shall be encompassed by a sidewalk easement or other easement, as approved by this Department.
- 2.13 **GATES:** Gates are not permitted on County right of way for public roads without authorization of the Board of Supervisors. Gates must not create a traffic hazard and must provide an appropriate turnaround in front of the gate. Existing gates shall be evaluated for conformance.
- 2.14 **COMPLETION OF SIDEWALK IMPROVEMENTS:** Sidewalk improvements may be deferred until such time as a building permit is pulled. Each building permit pulled will require that an ADA accessible sidewalk be constructed to connect the subject lot to the existing pedestrian network outside of the subdivision. Depending on the lot being built upon, this may include constructing sidewalk in front of numerous vacant lots within the subdivision. Sidewalk improvements must be completed prior to the “final” of the building permit. Any sidewalk damaged during construction will need to be replaced prior to the “final” of the building permit.
- 2.15 **FENCING:** Applicant shall replace the existing fence along the north line of the subdivision. The replacement fence shall be constructed one a lot-by-lot basis as each lot is developed. The fence shall be completed prior to building "final". This requirement shall be noted on the development plan. [Added by the Planning Commission on 12/03/2015]

### **3.0 DRAINAGE**

- 3.1 **DRAINAGE ISSUES:** Applicant shall be responsible to correct any involved drainage problems associated with the subdivision to the satisfaction of this Department.
- 3.2 **DRAINAGE REPORT:** Applicant must submit a complete hydraulic report and drainage plan regarding the subdivision for review and approval by this Department. This may require the construction of drainage facilities on-site and/or off-site in a manner and location approved by this Department.
- 3.3 **STORM WATER QUALITY:** Applicant shall include within the project site the implementation of Best Management Practices (BMPs) to prevent storm water pollution. BMPs include, but are not limited to, stenciling drainage inlets.

- 3.4 **DETENTION FACILITIES:** Pursuant to McKinleyville Community Plan Policy 3310(5), this project is required to construct detention facilities in a manner and location approved by this Department. In general, storm flows from the 100-year ( $Q_{100}$ ) storm shall be detained so as to release water from the site at a rate no greater than the predevelopment 2-year ( $Q_2$ ) storm flows. Contact this Department regarding any questions.

If the site conditions do not allow for detention, then infiltration may be considered by the Department as an alternative.

- 3.5 **DRAINAGE FEES:** Applicant must conform to Humboldt County Code Section 328.1-16 regarding McKinleyville Drainage Area Fees.

3.6 **LOW IMPACT DEVELOPMENT (LID):**

The subdivision is required to comply with County Code § 337-13. The applicant shall submit a Storm Water Information Sheet for review and approval by the County. The improvement plans must incorporate LID strategies for the entire subdivision, including roads, lots, and other areas.

At the time that the subdivision improvements are constructed, the LID elements related to an individual lot may be deferred until such time as the lot is developed. It is intended that any deferred LID strategies shown on the improvement plans for a lot are conceptual in nature and subject to adjustment/refinement at the time that the building permit is applied for. Any deferred LID improvements must be shown and identified on the Development Plan.

When there will be deferred LID improvements, a separate sheet in the improvement plans shall be provided for the LID concepts proposed for the individual lots. It is intended that this sheet will be attached to the development plan to facilitate issuance of a building permit at a later time.

Each lot in the subdivision is considered a regulated project.

## 4.0 GRADING

- 4.1 **SOILS REPORT:** Pursuant to Humboldt County Code Section 331-14 (E)(5), applicant shall provide a soils engineering report that addresses the entire subdivision. The report shall include sufficient detail to enable the Building Official to issue building permits for each lot within the subdivision.

Pursuant to Humboldt County Code Section 331-14 (H)(6)(b)(3), the Applicant shall file a copy of the soils engineering report with the Chief Building Official.

- 4.2 **GRADING PLAN:** Pursuant to Humboldt County Code Section 331-14 (H)(6)(b)(1), the applicant shall submit an engineered preliminary (rough) grading plan addressing the entire project construction area to this Department for review and approval. The purpose of the grading plan is to establish building pads that will drain to the roads (or other approved drainage course) without creating lot drainage from one lot to flow across the buildable area of adjacent lots.

- 4.3 **GRADING CRITERIA:** Each lot shall have a building pad graded to a maximum of 2% per Humboldt County Code Section 331-14 (H)(3)(d), unless waived by this Department. Building pads shall be of a sufficient size to accommodate anticipated future structures.

The elevation of the building pad shall be established so that a driveway from the building pad to the back of sidewalk will have a minimum slope of 1% and a maximum slope of 16%.

If sidewalk is not required, then the driveway slope will be measured to the back of driveway apron.

- 4.4 **CONSTRUCTION TIMING:** Grading within the subdivision or off-site rights of way shall **not** occur prior to approval of a grading plan by this Department. Construction of improvements or grading for this project will not be allowed to occur between October 15 and April 15 without permission of this Department.

- 4.5 **DATUM:** Grading plans shall be tied into elevation datum approved by this Department. Projects located within McKinleyville Community Services District (MCSD) area shall be tied to MCSD elevation datum unless waived by this Department.

- 4.6 **EROSION CONTROL:** Pursuant to Humboldt County Code Section 331-14 (H)(6)(d)(1), an erosion control plan (aka, sediment control plan, Storm Water Pollution Prevention Plan, etc.) addressing erosion from storm water runoff and wind shall accompany the grading plan.

For construction sites equal to or greater than one (1) acre, a Notice of Intent (NOI) and permit registration documents are required to be filed with the State Water Quality Control Board. A copy of the State's receipt of the approved NOI shall be provided to this Department prior to the start of construction.

## 5.0 MAINTENANCE

- 5.1 **MAINTENANCE OF IMPROVEMENTS:** The improvements to be constructed as part of this subdivision will not be maintained by the County. Pursuant to Humboldt County Code Section 323-2 (b) regarding Private Lanes, the Applicant must provide a permanent maintenance plan acceptable to this Department for all improvements including, but not limited to, the following: roads, drainage systems (pipes, drainage inlets, detention basins), pedestrian facilities, and landscape areas. An engineer's estimate for the cost of yearly maintenance must be approved by this Department. Maintenance shall be provided by a maintenance association, district, or other means as approved by this Department. More than one maintenance plan may be needed

Based upon the tentative map, it appears that the following will need to be maintained by a maintenance plan:

- A maintenance plan for all facilities within the proposed subdivision.
- A maintenance plan for the non-county maintained road known as Midtown Court.
- A maintenance plan for the storm water detention basin.

If a maintenance association currently exists for the access road, applicant shall attempt to the satisfaction of this Department to annex the subdivision into the existing road maintenance association. That portion of this condition regarding road maintenance may be

waived if the applicant provides evidence satisfactory to this Department that the subject property already belongs to a maintenance association for the access road(s).

A maintenance plan is not required for driveways; as driveways serve only one parcel. A maintenance plan is *optional* for roads that serve only two parcels. A maintenance plan is required for roads serving three or more parcels.

A maintenance plan for projects that contain detention facilities shall include, but is not limited to, the following:

- (a) A schedule for the periodic monitoring of the detention facilities. At a minimum, the detention facilities shall be monitored at least once each year between April 15 and October 15.
- (b) A system to monitor the basins in a timely manner after significant rain fall events.
- (c) Monitoring shall be done by a qualified professional as approved by this Department.
- (d) Monitoring shall include an annual written report identifying (1) the condition of the facilities; (2) the recommended maintenance needed for the facilities to function as originally constructed or as required by subsequent regulation; and (3) certification that the maintenance was completed to the satisfaction of a qualified professional. The report shall be submitted no later than October 31 of each year to this Department.
- (e) A financially secured procedure that will ensure that maintenance is identified and subsequently performed in a timely manner.
- (f) For infiltration basins, wet weather testing of the percolation rate of the basin consistent with Department of Environmental Health standards for determining the percolation rates for septic systems. Percolation rate testing shall be done every five (5) years.

5.2 **MAINTENANCE AGREEMENTS:** Any agreements regarding the maintenance of the detention facilities between the applicant and a public entity or Homeowners Association may be required to be approved by County Counsel and the County Risk Manager.

**6.0 DEVELOPMENT PLAN:** The following are required for all development plans:

6.1 The development plan shall be legibly drawn to a convenient scale on 22"x34" (or 24"x36") mylar, in black ink, unless approved otherwise by this Department.

6.2 The development plan shall include a note substantially similar to the following: "See the subdivision map on file with the County Recorder for easements that existed at the time the map was filed. Additional easements may have been established after the map was filed. Refer to a current title report for all easements. Refer to the filed subdivision map for exact lot dimensions."

6.3 The development plan shall include the following to the satisfaction of this Department:

- (a) When roads or drainage facilities are not to be maintained by the County, then clearly state next to the facility "NOT COUNTY MAINTAINED".

- (b) When minimum finished floor elevations must be adhered to, the plan shall state the minimum elevation and the referenced benchmark.
- (c) If prepared for the project, reference the soils report; including a statement substantially similar to: "See soils report prepared by \_\_\_\_\_, Project No. \_\_\_\_\_, dated \_\_\_\_\_, for recommendations, inspections, and special requirements required for development of this subdivision."
- (d) A statement substantially similar to: "All pedestrian facilities must be ADA compliant."
- (e) When improvement plans have been prepared in conjunction with proposed subdivision, include a statement substantially similar to: "Improvement plans for roads, driveways, and drainage, etc. are on file with the Department of Public Works".
- (f) For parcels that could be further subdivided: Provide information on the development plan to assist future owners in developing the parcels in a manner that preserves the maximum, future subdivision potential. This may include showing "potential" building setbacks for ultimate development. It is the intent of this condition that any "potential" setbacks are for information only and are not actual setback requirements to be adhered to.
- (g) Show a minimum setback of 20 feet from garage entrances for vehicles from easements created as a condition of tentative map approval or existing for the purpose of moving automotive vehicles, bicycles, pedestrians, or animals. Typically, this is 29 feet from the curb.
- (h) Provide a note identifying the maximum finished floor elevations for garage slabs based upon holding minimum setback of 20 feet to the garage door from back of sidewalk. The slab elevation should be relative to the flowline of the street at the centerline of the driveway. The maximum elevation is typically around 2.5 feet.
- (i) A typical section showing the location of the curbs and sidewalks with respect to the right of way lines.
- (j) Place the following note when landscaping is required along the frontage of lots within street rights of way: "Landscaping within the street right of way along the frontage of a lot shall be the maintenance responsibility of the individual lot owner. The landscaping was required as a condition of the approval of the subdivision and must not be removed without approval of the Planning & Building Department of the County of Humboldt or their successor."
- (k) For projects with a subdivision agreement, include the following note: "This subdivision was approved with requirements to construct improvements. At the time the subdivision map was filed, the improvements were not completed. The developer has entered into a subdivision agreement with the County to defer construction of these improvements. **Subdivision improvements must be completed within the timelines specified in the agreement. In general, building permits cannot be obtained until the required improvements are constructed to the satisfaction of the County.** The improvements required in the subdivision agreement are shown on the improvement plans prepared by



- 7.3 **MAINTENANCE:** Landscaping along the frontage of public streets is the responsibility of the adjacent lot owner. Landscaping along the frontage of private roads is the responsibility of the road maintenance association for the private road or is the responsibility of the adjacent lot owner.

This Department **may** maintain landscaping along collector or arterial roads when permanent funding source is made available.

- 7.4 **LANDSCAPING GOALS:** When on-site landscaping is required, any unimproved county right of way contiguous with the property shall be incorporated into the landscaping plan. Any landscaping shown within the County right of way shall be in addition to any required landscaping areas and shall not be counted towards meeting a landscaping goal.

7.5 **WATER EFFICIENT LANDSCAPE GOALS:**

For projects with an aggregate landscape area equal to or greater than 500 square feet, landscaping design and documentation shall be completed in accordance with County Code §331-11(o). After approval, the applicant shall submit a copy of the Water Efficient Landscape Worksheet to the local water purveyor.

// END //

EXHIBIT A



DEPARTMENT OF PUBLIC WORKS  
**C O U N T Y O F H U M B O L D T**

MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579  
AREA CODE 707

PUBLIC WORKS BUILDING  
SECOND & L ST., EUREKA  
FAX 445-7409

CLARK COMPLEX  
HARRIS & H ST., EUREKA  
FAX 445-7388

ON-LINE  
WEB: CO.HUMBOLDT.CA.US

ADMINISTRATION	445-7491	NATURAL RESOURCES	445-7741
BUSINESS	445-7652	NATURAL RESOURCES PLANNING	267-9540
ENGINEERING	445-7377	PARKS	445-7651
FACILITY MANAGEMENT	445-7493	ROADS	445-7421

LAND USE 445-7205

---

---

**LAND USE DIVISION INTEROFFICE MEMORANDUM**

---

---

TO: Cliff Johnson, Supervising Planner

FROM: Ken Freed, Assistant Engineer

DATE: 09/06/2023

RE: **BRIGHT VIEW HOMES LLC, APN 510-121-026, PLN-2023-18247 FMS**

This tentative map is the re-application of an expired tentative map. The 09/05/2023 conditions of approval shown reflect what the Planning Commission previously approved on 12/03/2015 with the exception of Item 3.6 regarding low impact development requirements which came into effect after the expired tentative map was approved. And in addition, Item 7.5 regarding water efficient landscape goals which came into effect after the expired tentative map was approved.

**APPROVED IMPROVEMENT PLANS:** Prior to the expiration of the tentative map, Public Works approved the subdivision improvement plans and the applicant began construction. Construction ceased when the tentative map expired.

These subdivision improvements plans can be utilized for the proposed subdivision. Changes to the plans can be shown as "delta change" revisions. This allows the existing approved subdivision improvement plans to be updated at minimal time and expense to the applicant.

**LID:** At the time that the prior tentative map was submitted, the entire subdivision did not need to comply with LID; only development on the new lots was required to comply with LID. Because the tentative map has expired, the entirety of the new tentative map is considered regulated and is subject to LID. The improvement plans need to be modified to address LID.

**SIDEWALKS:** The Planning Commission approved the project eliminating sidewalks along Midtown Court. If the Planning Commission determines that sidewalks are now warranted for the project, sidewalks can easily be added as a "delta change" on the approved improvement plans. More specifically, Section B on sheet 6 can have the sidewalk added on the east side in the PUE area. The construction note would read: Construct 5 foot wide PCC sidewalk including curb ramps at the turn around.

// END //