



DEPARTMENT OF PUBLIC WORKS
C O U N T Y O F H U M B O L D T
MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579
AREA CODE 707

ON-LINE

WEB: CO.HUMBOLDT.CA.US

PUBLIC WORKS BUILDING
SECOND & L ST., EUREKA
FAX 445-7409

CLARK COMPLEX
HARRIS & H ST., EUREKA
FAX 445-7388

ADMINISTRATION	445-7491	NATURAL RESOURCES	445-7741
BUSINESS	445-7652	NATURAL RESOURCES PLANNING	267-9540
ENGINEERING	445-7377	PARKS	445-7651
FACILITY MANAGEMENT	445-7493	ROADS	445-7421

LAND USE	445-7205
----------	----------

LAND USE DIVISION INTEROFFICE MEMORANDUM

TO: Devin Sutfin, Associate Planner, Planning & Building Department

FROM: Ken Freed, Assistant Engineer 

DATE: 08/07/2023

RE: **DANIELS; APN 111-121-037; PLN-2023-18280**

ROAD: Sea Court (4A041) is a paved County maintained road. An encroachment permit is required for the residential driveway and parking lane.

SITE PLAN: Submitted site plan does not appear to provide the required parking spaces in the correct locations. To accommodate all required parking, it appears that the applicant will be required to construct an asphalt parking lane along the frontage of the parcel. In addition, the propane tank and short section of fence, on the south property line, shall be removed from the County road right of way. Applicant shall provide a revised site plan to the Department for approval.

MS4 AREA: The subject property is located within the municipal separate storm sewer system (MS4) boundary area. Development of the property is required to comply with MS4 permit requirements. The Applicant is advised to ensure that MS4 requirements for the proposed project can be achieved prior to the project being heard by the Planning Commission (or Zoning Administrator). [Reference: National Pollutant Discharge Elimination System (NPDES) General Permit For Waste Discharge Requirements (WDRS) for Storm Water Discharges From Small Municipal Separate Storm Sewer Systems (MS4S), Order No. 2013-0001-DWQ, NPDES No. CAS000004 adopted 02/05/2013, Section E.12; Humboldt Low Impact Development Stormwater Manual version 3.0 (08/18/2021), Part A, (Table 1), Part 2, and Part 3 (Section 1.4)]

Development of property is also required to comply with provisions for point source discharges of stormwater and non-point source waste discharges as specified in the General Exception to the California Ocean Plan for select Discharges into Areas of Special Biological Significance (ASBS), Including Special Protections for Beneficial Uses, Sections I.A and I.B (State Water Resources Control Board Resolution 2012-0031 as amended 6/19/2012).

The following conditions are recommended: Our review of this project is limited to what is shown on the submitted plot plan. If other facilities not shown on the plot plan will be constructed, contact this Department immediately for approval **before** construction. This

\\all\humco\pwrk\pwrk-shared\land use_landdevprojects\referrals\111-121-037 daniels pln-2023-18280 cdp.doc

Department has regulations regarding facilities such as retaining walls, fence site visibility, drainage culverts, and parking lanes within the County right of way. This Department has included general statements for facilities that may not be included on the plot plan.

(1) Applicant must apply for and obtain an encroachment permit for the construction of a residential driveway on Sea Court. [reference: County Code section 411-11 (a)(b)]

(2) The permit will require the driveway entrance to be surfaced with asphalt concrete or Portland cement concrete. The paved area shall extend a minimum of 20 feet back from the edge of the existing roadway pavement and be flared approximately 30 feet to accommodate vehicle wheel turning movement at the intersection with the County road. The driveway shall intersect the County road at a 90° angle. The driveway grade shall not exceed 2% in the first 20 feet. [reference: County Code sections 313-109.1.3.2.5 and 411-51 (b)(3)]

(3) The County road is not constructed to allow on-street parking. All parking must be developed on-site, or applicant must construct a parking lane along the County road in a manner approved by this Department. All parking required by Code must be constructed prior to occupancy of building or “final” issued for building permit. [reference: County Code section 313-109.1 et seq.]

(4) Site visibility must be maintained at the residential driveway entrance. [reference: County Code section 341-1 et seq.]

(5) All retaining walls shall be constructed on the property. **NO retaining walls shall be constructed in the County right of way.**

(6) After the building pad and driveway have been rough graded, the applicant shall contact the Public Works inspector to ensure that the proposed driveway grades are in conformance with County Code, prior to construction of the building foundation and/or driveway. [reference: County Code section 411-15]

(7) Applicant shall be responsible to correct any involved drainage problems within the County road right of way to the satisfaction of this Department.

(8) Low Impact Development (LID): The subject property is located within the municipal separate storm sewer system (MS4) boundary area. Development of the property is required to comply with MS4 permit requirements. The Applicant is advised to ensure that MS4 requirements for the proposed project can be achieved prior to the project being heard by the Planning Commission (or Zoning Administrator). [Reference: National Pollutant Discharge Elimination System (NPDES) General Permit For Waste Discharge Requirements (WDRS) for Storm Water Discharges From Small Municipal Separate Storm Sewer Systems (MS4S), Order No. 2013-0001-DWQ, NPDES No. CAS000004 adopted 02/05/2013, Section E.12; Humboldt Low Impact Development Stormwater Manual version 3.0 (08/18/2021), Part A, (Table 1), Part2, and Part 3 (Section 1.4)]

Development of property is also required to comply with provisions for point source discharges of stormwater and non-point source waste discharges as specified in the General Exception to the California Ocean Plan for select Discharges into Areas of Special Biological Significance (ASBS), Including Special Protections for Beneficial Uses, Sections I.A and I.B (State Water Resources Control Board Resolution 2012-0031 as amended 6/19/2012).

Informational note:

(9) **FENCES/GATES:** Pursuant to County Code Section 411-11 (j) and California Streets & Highways Code Sections 1481 & 1482, fences are not allowed within the public right of way of County maintained roads. Prior to constructing any fences along (or near) the right of way line, the applicant is advised to consult with the Department of Public Works Encroachment Permit Office at 707.445.7205.

It is important to note that fences constructed outside of the public right of way are still subject to the County's visibility Ordinance (County Code Section 341-1). Fences and gates on private property may need to be setback further to comply with the County Visibility Ordinance.

Fences and gates taller than 6 feet may require a building permit. The applicant is advised to consult with the Planning and Building Department – Building Division at 707.445.7245 prior to constructing any fences or gates.

// END //