

DRY WEATHER WATER PRODUCTION TEST RECOVERY DATA

Owner: Demeter Gardens, LLC

APN: 206-331-028

Well Location latitude: 40.53707

Longitude: -124.05013

_____1/4	_____1/4	_____1/4	Section: 22	Township: 2N	Range 2E
----------	----------	----------	--------------------	---------------------	-----------------

Type of Water Measuring Equipment: Water Meter

Date Test Performed: August 1, 2025

Company Performing Test: Fisch Drilling & Pump, Inc.

Measured By: Matthew F., Jacob M.

TIME DATA	WATER LEVEL DATA	DISCHARGE DATA
<u>PUMP ON</u> Date: 8/1/25 Time: 07:00 (t ₀) <u>PUMP OFF</u> Date: 8/1/25 Time: 23:00 (t ₁) <u>DURATION OF AQUIFER TEST</u> Pumping: 16 hr Recovery: 3 min	STATIC WATER LEVEL: 24.5' MEASURING POINT: Well head HEIGHT OF MEASURING POINT ABOVE GROUND: 23"	HOW WAS DISCHARGE MEASURED? Water Meter DEPTH OF PUMP/AIRLINE: 160'

Recovery Data:

Date	Clock Time	Time Since Pump Shutoff (min.) t ₁	Recovery Water Level Measurement (ft)	Comments on Factors Affecting Test Data
8/1/25	23:00	0	27.9	
8/1/25	23:01	1	24.10	
8/1/25	23:02	2	24.7	
8/1/25	23:03	3	24.5	Recovered