

EXHIBIT A



DEPARTMENT OF PUBLIC WORKS
C O U N T Y O F H U M B O L D T

MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579
AREA CODE 707

PUBLIC WORKS BUILDING
SECOND & L ST., EUREKA
FAX 445-7409

CLARK COMPLEX
HARRIS & H ST., EUREKA
FAX 445-7388

ON-LINE
WEB: CO.HUMBOLDT.CA.US

ADMINISTRATION	445-7491	NATURAL RESOURCES	445-7741
BUSINESS	445-7652	NATURAL RESOURCES PLANNING	267-9540
ENGINEERING	445-7377	PARKS	445-7651
FACILITY MANAGEMENT	445-7493	ROADS	445-7421

LAND USE 445-7205

LAND USE DIVISION INTEROFFICE MEMORANDUM

TO: Chris Lohofener, Senior Planner

FROM: Kenneth Freed, Assistant Engineer 

RE: **SUBDIVISION REQUIREMENTS - IN THE MATTER OF MEEMEEMINE, LLC, PLN-2024-19114, APN 308-271-001, FOR APPROVAL OF A TENTATIVE MAP, CONSISTING OF 14.3 ACRES INTO 2 PARCELS**

12/18/2024 **DRAFT**

The following requirements and standards are applicable to this project and must be completed to the specifications and satisfaction of the Department of Public Works (Department) before the subdivision map may be filed with the County Recorder. If there has been a substantial change in the project since the last date shown above, an amended report must be obtained and used in lieu of this report. Prior to commencing the improvements indicated below, please contact the Subdivision Inspector at 445-7205 to schedule a pre-construction conference.

These recommendations are based on the tentative map prepared by Omsberg & Preston dated November 13, 2024 and dated as received by the Humboldt County Planning Division on November 14, 2024.

NOTE: All correspondence (letters, memos, faxes, construction drawings, reports, studies, etc.) with this Department must include the Assessor Parcel Number (APN) shown above.

READ THE ENTIRE REPORT BEFORE COMMENCING WORK ON THE PROJECT
--

1.0 MAPPING

1.1 EXPIRATION OF TENTATIVE MAP

Applicant is advised to contact the Planning & Building Department to determine the expiration date of the tentative map and what time extension(s), if any, are applicable to the project. Applicant is responsible for the timely filing of time extension requests to the Planning & Building Department.

Applicant is responsible for completing all of the subdivision requirements prior to expiration of the tentative map. Applicant is advised to promptly address all of the subdivision requirements in order to avoid the tentative map expiring prior to completion of the subdivision requirements. Applicants are encouraged to contact a land development professional for advice on developing a realistic schedule for the processing of the project.

1.2 MAP TYPE

Applicant must cause to be filed a subdivision map showing monumentation of all property corners to the satisfaction of this Department in compliance with County Code §326-31. Subdivision map checking fees shall be paid in full at the time the subdivision map is submitted for checking. County Recorder fees shall be paid prior to submittal of the map to the County Recorder for filing. The subdivision map must be prepared by a Land Surveyor licensed by the State of California -or- by a Civil Engineer registered by the State of California who is authorized to practice land surveying.

All Department charges associated with this project must be paid in full prior to the subdivision map being submitted to the County Recorder for filing.

Applicant shall submit to this Department an electronic copy of the subdivision map, in pdf format, as filed by the County Recorder. [Reference: Government Code §66466(f)]

Prior to submitting the subdivision map to the County Surveyor for map check, applicant shall submit the subdivision map to the utility providers to provide input on necessary public utility easements. Copies of the responses from the utility providers shall be included with the first submittal of the subdivision map to the County Surveyor.

1.3 DEPOSIT

Applicant shall be required to place a security deposit with this Department for inspection and administration fees as per County Code §326-13 prior to review of the improvement plans, review of the subdivision map, or the construction of improvements, whichever occurs first.

1.4 EASEMENTS

All easements that encumber or are appurtenant to the subdivision shall be shown graphically on the subdivision map. Those easements that do not have a metes and bounds description shall be noted on the subdivision map and shown as to their approximate location.

1.5 EASEMENT COORDINATION AND SIGN-OFF

Provide sign-off from all utility companies that existing and proposed public utility easements shown on the subdivision map are adequate for their needs.

1.6 DEDICATIONS

The following shall be dedicated on the subdivision map, or other document as approved by this Department:

(a) PUBLIC ROAD: TABLE BLUFF ROAD (CO RD #3H270)

Public Road: Applicant shall cause to be dedicated on the subdivision map to the County of Humboldt an easement for public road purposes lying within 33 feet of the center line of the

County road. The applicant is only responsible to cause to be dedicated lands that are included within the boundary of the proposed subdivision.

Slopes: When cut and fill slopes adjacent to the road are proposed (or currently exist), applicant shall cause to be dedicated to the County of Humboldt a slope maintenance easement to a point 10 feet beyond the toe of fill slopes or top of cut slopes in a manner approved by this Department. The applicant is only responsible to cause to be dedicated lands that are included within the boundary of the proposed subdivision.

PUE: Applicant shall cause to be dedicated to the County of Humboldt on the subdivision map a 10 foot wide public utility easement (PUE) adjacent to the right of way for the road or as otherwise approved by this Department. Additional PUEs shall be dedicated in a manner, width, and location approved by this Department.

(b) PUBLIC ROAD: EEL RIVER DRIVE (CO RD #C3H160)

Public Road: Applicant shall cause to be dedicated on the subdivision map to the County of Humboldt an easement for public road purposes lying within 50 feet of the center line of the County road. The applicant is only responsible to cause to be dedicated lands that are included within the boundary of the proposed subdivision.

Slopes: When cut and fill slopes adjacent to the road are proposed (or currently exist), applicant shall cause to be dedicated to the County of Humboldt a slope maintenance easement to a point 10 feet beyond the toe of fill slopes or top of cut slopes in a manner approved by this Department. The applicant is only responsible to cause to be dedicated lands that are included within the boundary of the proposed subdivision.

PUE: Applicant shall cause to be dedicated to the County of Humboldt on the subdivision map a 10 foot wide public utility easement (PUE) adjacent to the right of way for the road or as otherwise approved by this Department. Additional PUEs shall be dedicated in a manner, width, and location approved by this Department.

(c) NON-VEHICULAR ACCESS

Applicant shall cause to be dedicated to the County of Humboldt on the subdivision map a 1-foot wide non-vehicular access strip adjacent to Eel River Drive. The location shall be as shown on the tentative map, or as otherwise approved by this Department. Said easement shall be dedicated in manner and location as approved by this Department.

(d) NEIGHBORHOOD BOX UNIT (NBU) MAILBOXES

Prior to submittal of the subdivision map, provide a sign-off from the Post Office on the location of the neighborhood box unit. Applicant shall cause to be dedicated on the subdivision map additional sidewalk easements as necessary to accommodate the NBU.

Note: The Post Office may not require an NBU for this project.

1.7 LINES OF OCCUPATION

Applicant shall provide prospective buyers with notice of any fences that are not on the property lines.

2.0 IMPROVEMENTS

2.1 CONSTRUCTION PLANS

<NONE>

2.2 DRIVEWAYS

All access openings (existing and proposed) shall conform to Humboldt County Code § 341 regarding visibility. All access openings (existing and proposed) shall intersect the road at a 90° angle, unless otherwise approved by this Department.

All access openings (existing and proposed) shall be paved with hot mix ("asphalt") for the width of the driveway and a distance of 25 feet or to the grade break for steep driveways (15%+) from the edge of the County road. Existing driveways serving developed parcels need to be paved prior to filing of the subdivision map. The width of the driveway shall be as approved by this Department.

Any proposed access openings to the County road will require encroachment permits from this Department. The proposed access openings will be evaluated after application is received.

2.3 STRUCTURAL SECTION

The access road(s) shall be constructed to a structural section recommended in the soils report and as approved by this Department.

- (a) **For paved road surfaces**, the structural section shall include a minimum of 0.2 feet of Caltrans Type A 1/2" hot mix ("asphalt") over 0.67 foot of Caltrans Class 2 aggregate base. If required by this Department, the structural section of all roads shall be determined by Caltrans R-Value method using a Traffic Index (T.I.) approved by this Department. Based upon soil conditions, this Department may also require a geotextile fabric to be placed on top of the sub grade.
- (b) When widening hot mix ("asphalt") roads, the widened road shall be paved with hot mix. A sawcut is required to ensure a uniform joint between the existing and new pavements. The location of the sawcut shall be approved by this Department based upon the condition of the existing road surface.

Access roads and driveways may include decorative accent treatments such as, but not limited to, stamped concrete or decorative brick pavers. Decorative accent treatments must provide appropriate traction for pedestrians, bicycles, and vehicles. **Decorative access treatments are not permitted within the public right of way**, unless approved in writing by this Department.

2.4 UNKNOWN IMPROVEMENTS

Other on-site and/or off-site improvements may be required which cannot be determined from the tentative map and/or preliminary improvement plans at this time. These improvements will be determined after more complete improvement plans and profiles have been submitted to the County for review.

2.5 UTILITIES

The proposed improvements may require the undergrounding or relocation of existing facilities at the expense of the applicant. Undergrounding of existing facilities, relocation of existing facilities, or construction of new facilities shall be completed prior to constructing the structural section for the roadway.

If any utilities are required to be installed as a condition of tentative map, the utility work shall be completed prior to constructing the structural section for the road. All laterals shall be extended onto each lot and marked in a manner that they will be easily located at the time of individual hookups. A letter of completion of all work from each involved utility company shall be submitted prior to constructing the roadway structural section. Any utilities that need to be relocated shall be done solely at the subdivider's expense.

Applicant shall remove any abandoned utilities (natural gas, electrical, cable tv, etc.) within the public right of way fronting the subdivision or within the subdivision as directed by this Department.

2.6 PERMITS

Pursuant to County Code §411-11 (a)&(b), an encroachment permit is required to be obtained prior to construction from this Department for all work within the right of way of a County maintained road.

2.7 NEIGHBORHOOD BOX UNIT (NBU) MAILBOXES

When clustered mailboxes (neighborhood box units) are required by the Post Office, applicant shall obtain approval for the location of the mailbox unit from the Post Master. The pad for the mailbox unit shall be constructed as part of the subdivision and shall be encompassed by a sidewalk easement or other easement, as approved by this Department. If the NBUs will not be installed by the Post Office, the subdivider shall install the NBUs as part of the subdivision.

2.8 GATES

Gates are not permitted on County right of way for public roads without authorization of the Board of Supervisors. Gates must not create a traffic hazard and must provide an appropriate turnaround in front of the gate. Existing gates shall be evaluated for conformance.

2.9 COMPLETION OF IMPROVEMENTS ON PARCEL MAP SUBDIVISION

When improvements are not constructed before the subdivision map is filed with the County Recorder, the following apply:

- (a) Pursuant to Government Code § 66411.1 (improvement timing), fulfillment of reasonable on-site and off-site construction requirements may be imposed prior to Parcel Map filing with the County Recorder if found necessary for (1) public health and safety, or (2) orderly development of the area. The following improvements are necessary for the public health and safety, or orderly development of the area and shall be completed: (1) within two (2) years after the filing date of the Parcel Map, or (2) prior to issuance of a building permit on any property subject to this notice, or (3) prior to any other grant of approval for any property subject to this notice, whichever occurs first:

Item #2.2 for Parcel A

- (b) The following improvements shall be completed: (1) prior to issuance of a building permit on any property subject to this notice, or (2) prior to any other grant of approval for any property subject to this notice, whichever occurs first:

<NONE>

- (c) The following improvements shall be completed: (1) within two (2) years after the issuance of a Building Permit on any property subject to this notice, or (2) prior to issuance of an Occupancy Permit for any property subject to this notice, whichever occurs first:

Item #2.2 for Parcel A & Parcel B

- (d) The following note shall be placed on the development plan:

"This subdivision was approved with requirements to construct improvements. At the time the parcel map was filed, the improvements were not completed. The subdivision improvements must be completed within the timelines specified in the *Notice of Construction Requirements*. Building permits or other development permits cannot be obtained until the required improvements are constructed to the satisfaction of the County. The improvements required in the *Notice of Construction Requirements* are shown on the improvement plans prepared by _____, dated _____, and are signed as approved by the County on _____. Contact the Land Use Division of the Department of Public Works for details."

The Department shall cause to be recorded at the time of filing of the parcel map with the County Recorder a *Notice of Construction Requirements*.

3.0 DRAINAGE

3.1 PRELIMINARY DRAINAGE REPORTS

Any submitted reports have not been through a thorough engineering review. Detailed review and approval will be provided after the tentative map has been approved. This also applies to low impact development submittals.

3.2 DRAINAGE ISSUES

Applicant shall be responsible to correct any involved drainage problems associated with the subdivision to the satisfaction of this Department.

3.3 DRAINAGE REPORT

Applicant must submit a complete hydraulic report and drainage plan regarding the subdivision for review and approval by this Department. The report and plan must be prepared by a Civil Engineer registered by the State of California. This may require the construction of drainage facilities on-site and/or off-site in a manner and location approved by this Department.

4.0 GRADING

<NONE>

5.0 MAINTENANCE

<NONE>

6.0 DEVELOPMENT PLAN

<NONE>

7.0 LANDSCAPING

<NONE>

// END //



EXHIBIT A

DEPARTMENT OF PUBLIC WORKS
C O U N T Y O F H U M B O L D T
MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579
AREA CODE 707

ON-LINE
WEB: CO.HUMBOLDT.CA.US

PUBLIC WORKS BUILDING	
SECOND & L ST., EUREKA	
FAX 445-7409	
ADMINISTRATION	445-7491
BUSINESS	445-7652
ENGINEERING	445-7377
FACILITY MANAGEMENT	445-7493
NATURAL RESOURCES	445-7741
NATURAL RESOURCES PLANNING	267-9540
PARKS	445-7651
ROADS	445-7421

CLARK COMPLEX	
HARRIS & H ST., EUREKA	
FAX 445-7388	
LAND USE	445-7205

LAND USE DIVISION INTEROFFICE MEMORANDUM

TO: Chris Lohofener, Associate Planner

FROM: Kenneth Freed, Assistant Engineer

DATE: December 18, 2024

RE: MeeMeeMine LLC PLN-2024-19114 Parcel Map

PRELIMINARY SUBDIVISION REPORT: A preliminary report was submitted in lieu of a preliminary subdivision report as specified in County Code §323-6(c).

TENTATIVE MAP: Although the setbacks dimensioned from Table Bluff Road are not measured from the right of way line the Public Works Department does not require a revised tentative map.

DEFERRED IMPROVEMENTS: Frontage improvements to Parcel A (an existing developed parcel) must be constructed per the Department's subdivision requirements. Pursuant to Government Code §66411.1, the Department recommends that the frontage improvements on Parcel A be completed within twenty-four (24) months from the date that the subdivision map is filed with the County Recorder; or prior to issuance of a development permit (or building permit) for Parcels A or B, whichever occurs first. This is based upon the need for public safety and orderly development of the surrounding area.

The construction of the subdivision improvements for Parcel B may be deferred to the time that a development permit (or building permit) is issued.

The Planning Commission needs to make findings pursuant to Government Code §66411.1 (improvement timing) requiring the fulfillment of reasonable on-site construction requirements that are being imposed prior to Parcel Map filing with the County Recorder due to (1) public health and safety, and/or (2) orderly development of the area.

Frontage improvements that remain uncompleted prevent the public from benefitting from those deferred improvements. Requiring these improvements to be constructed sooner insures the safety of the public and promotes orderly development.