

State of California  
**Well Completion Report**  
Form DWR 188 Submitted 6/16/2020  
WCR2020-007614

For David Cuevas -  
(465 acres) 11607  
16016


Owner's Well Number \_\_\_\_\_ Date Work Began 06/02/2020 Date Work Ended 06/03/2020  
Local Permit Agency Humboldt County Department of Health & Human Services - Land Use Program  
Secondary Permit Agency \_\_\_\_\_ Permit Number 19/20-0819 Permit Date 05/14/2020

Well Owner (must remain confidential pursuant to Water Code 13752)		Planned Use and Activity	
Name	<u>David Cuevas</u>	Activity	<u>New Well</u>
Mailing Address	<u>P.O Box 3521</u>	Planned Use	<u>Water Supply Irrigation - Agriculture</u>
City	<u>Eureka</u>		
State	<u>CA</u>		
Zip	<u>95501</u>		

Well Location									
Address <u>0 Three Creeks Rd</u>					APN <u>522-023-01</u>				
City <u>Blue Lake</u>		Zip <u>95525</u>		County <u>Humboldt</u>		Township <u>07 N</u>			
Latitude <u>40 59 23.9049 N</u>		Longitude <u>-123 43 21.6832 W</u>		Range <u>04 E</u>		Section <u>16</u>			
Dec. Lat. <u>40.9899736</u>		Dec. Long. <u>-123.7226898</u>		Baseline Meridian <u>Humboldt</u>		Ground Surface Elevation _____			
Vertical Datum _____		Horizontal Datum <u>WGS84</u>		Elevation Accuracy _____		Elevation Determination Method _____			
Location Accuracy _____		Location Determination Method _____							

Borehole Information			Water Level and Yield of Completed Well		
Orientation	<u>Vertical</u>	Specify _____	Depth to first water	<u>80</u>	(Feet below surface)
Drilling Method	<u>Direct Rotary</u>	Drilling Fluid <u>Air</u>	Depth to Static _____		
Total Depth of Boring	<u>200</u>	Feet	Water Level	<u>115</u>	(Feet) Date Measured <u>06/04/2020</u>
Total Depth of Completed Well	<u>200</u>	Feet	Estimated Yield*	<u>7</u>	(GPM) Test Type <u>Pump</u>
			Test Length	<u>4</u>	(Hours) Total Drawdown _____ (feet)
			*May not be representative of a well's long term yield.		

Geologic Log - Free Form		
Depth from Surface Feet to Feet		Description
0	21	Brown Broken Rock
21	55	Hard Bedrock
55	80	Hard Bedrock w/ Quartz
80	108	Quartz w/ Bedrock
108	150	Soft Bedrock
150	200	Hard Bedrock



Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specifications	Wall Thickness (Inches)	Outside Diameter (Inches)	Screen Type	Slot Size if any (Inches)	Description
1	0	180	Blank	PVC	OD: 5.563 in.   SDR: 17   Thickness: 0.327 in.	0.327	5.563			
1	180	190	Screen	PVC	OD: 5.563 in.   SDR: 17   Thickness: 0.327 in.	0.327	5.563	Milled Slots	0.032	
1	190	200	Blank	PVC	OD: 5.563 in.   SDR: 17   Thickness: 0.327 in.	0.327	5.563			

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	20	Bentonite	Other Bentonite	3/8	
20	200	Filter Pack	Other Gravel Pack	3/8	Pea Gravel

**Other Observations:**

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	200	8

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name <u>RICH WELL DRILLING &amp; PUMP SERVICE INC</u>			
Person, Firm or Corporation			
1251 RAILROAD DRIVE		MC	CA 95519
Address		City	State Zip
Signed	<u>electronic signature received</u>	06/16/2020	902702
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

DWR Use Only											
CSG #	State Well Number				Site Code			Local Well Number			
					N						W
Latitude Deg/Min/Sec						Longitude Deg/Min/Sec					
TRS:											
APN:											