



Division of Environmental Health Referral Response

[check spelling](#)

03/18/2019		04/30/2019		BDOLF	Approved with Conditions ▼	<div>The well proposed to serve the project was improperly constructed and has not been approved by Environmental Health. Use of well is conditioned upon installation of a proper surface sanitary seal in accordance with the California Well Standards and approved by Environmental Health.</div> <input type="checkbox"/>
------------	---	------------	---	-------	----------------------------	--

“The well proposed to serve the project was improperly constructed and has not been approved by Environmental Health. Use of well is conditioned upon installation of a proper surface sanitary seal in accordance with the California Well Standards and approved by Environmental Health.”