

November 12, 2024

10524.00

Ashley Puhl
P.O. Box 451
Whitethorn, CA 95589

Attention: Ashley Puhl

Subject: Existing Grading at 499 Humboldt Loop, Shelter Cove, CA, APN 109-291-019

Dear Ashley:

LACO representatives visited 499 Humboldt Loop on August 21, 2023, and October 7, 2024. At the time of the site visits, it was observed that the existing grading resulted in less than an estimated 40 cubic yards of earthwork moved. The existing cut slopes are less than five (feet) in height. Most of the disturbed area appears revegetated, and the graded areas appear stabilized. No re-grading is recommended at this time, however, the owner should be observant for any signs of instability, sliding or scarping at the site. Should any signs of instability emerge they should immediately consult a registered engineer or geotechnical consultant for further assessment. It is recommended that fill slopes onsite remain free from additional organic material.

Sincerely,
LACO Associates



Rod Wilburn, PE
Principal Civil Engineer