

Division of Environmental Health Referral Response

Date Referred: May 4, 2023




Date of Response: May 16, 2023

Project: PLN-2020-16866-MOD01

APNs:

216-082-002-000

216-082-006-000

5/4/2023 	5/16/2023 	JWHITTLESEY	Approved with Conditions 	<p>DEH has no record of the two water wells existing on APN 216-082-006 as shown on the provided site plan (prepared by Clearwater Ag Services, dated 4/7/22). Owner shall either provide evidence of permits, destroy the wells, legalize the wells through installation of new sanitary surface seals, or provide compelling evidence that the wells were installed prior to February, 1973.</p> <p>Processing and wholesale nursery activities must be supported by an approved onsite wastewater treatment system. Seasonal/outdoor cultivation sites may be supported by portable toilets. Applicant must obtain a permit for, and install, an approved onsite wastewater treatment system to support the processing/nursery locations and either install approved septic systems or provide portable toilets to cultivation areas.</p> <p>check spelling</p>
--	---	-------------	--	--