

RECEIVED

DEC 13 2017

State of California
Well Completion Report
 Form DWR 188 Submitted 12/13/2017
 WCR2017-006002

HUMBOLDT COUNTY DIVISION
 OF ENVIRONMENTAL HEALTH

Owner's Well Number 1 Date Work Began 12/12/2017 Date Work Ended 12/12/2017
 Local Permit Agency Humboldt County Department of Health & Human Services - Land Use Program
 Secondary Permit Agency _____ Permit Number 18/17-1272 Permit Date 07/05/2017

Well Owner (must remain confidential pursuant to Water Code 13752)

Name _____
 Mailing Address _____
 City _____ State CA Zip 95542

Planned Use and Activity

Activity Other - Modification- Installed
 Planned Use Water Supply Irrigation - Agriculture

Well Location

Address _____ APN 214-233-008
 City Redway Zip 95560 County Humboldt Township 03 S
 Latitude _____ N Longitude _____ W Range 03 E
 Deg. Min. Sec. Deg. Min. Sec. Section 23
 Dec. Lat. 40.1941660 Dec. Long. -123.8106990 Baseline Meridian Humboldt
 Vertical Datum _____ Horizontal Datum WGS84 Ground Surface Elevation _____
 Location Accuracy _____ Location Determination Method _____ Elevation Accuracy _____
 Elevation Determination Method _____

Borehole Information

Orientation Vertical Specify _____
 Drilling Method Auger Drilling Fluid Air
 Total Depth of Boring 135 Feet
 Total Depth of Completed Well 135 Feet

Water Level and Yield of Completed Well

Depth to first water _____ (Feet below surface)
 Depth to Static _____
 Water Level 50 (Feet) Date Measured 12/12/2017
 Estimated Yield* 18 (GPM) Test Type Pump
 Test Length 2 (Hours) Total Drawdown _____ (feet)
 *May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface Feet to Feet	Description
0 135	Franciscan Sandstone

Casings


Casing #	Depth from Surface Feet to Feet	Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0 135	Blank	PVC	OD: 5.563 in. SDR: 21 Thickness: 0.265 in.	0.265	5.563			

Annular Material

Depth from Surface Feet to Feet	Fill	Fill Type Details	Filter Pack Size	Description
0 20	Bentonite	Other Bentonite		Sanitary Seal

Other Observations:

ENTERED
 12-14-17



RECEIVED

DEC 13 2017

PROBLET CO. DIVISION
OF ENVIRONMENTAL HEALTH

RECEIVED


JUN 8 2017

HUMBOLDT CO. DIVISION
OF ENVIRONMENTAL HEALTH



MIRANDA

PHILIPS



DIRECTIONS

South on Hwy 101
To EXIT 650 (R)
TURN / WEST 100
ON FRENCH RD. (L)
GATE @ DEAD END
3 MILES UP RIDGE
TO HOME + WELL

PROPERTY
LINE



WELL +
SITE

PROPOSE
HOUSE
+ SEPTIC

3 MILES FROM 101 HWY
PROPERTY
LINE

RECEIVED


MAY - 4 2018

Humboldt County

RECEIVED

JUN 8 2017

HUMBOLDT CO. DIVISION
OF ENVIRONMENTAL HEALTH





Environmental Health
100 H Street, Suite 100, Eureka, CA 95501
phone: (707) 445-6215 fax: (707) 441-5699

Authorization for Access to Property

This form may be used in lieu of obtaining property owner's 'right of entry' authorization on the Water Well Application. Property owner's authorization must be received by Environmental Health prior to permit issuance.

I authorize the Department of Health and Human Services, Division of Environmental Health, access to my property for the purpose of the initial and final inspection of water well

APN 214-233-008

☒ construction

☐ destruction

☒ modification

Date 5.23.17

Property Owner's Name (print)

LOUIS PEELE

Property Owner's Signature

[Signature]