



HUMBOLDT COUNTY
PLANNING AND BUILDING DEPARTMENT
CURRENT PLANNING DIVISION
3015 H STREET, EUREKA, CA 95501 ~ PHONE (707) 445-7541

PROJECT REFERRAL TO: Health and Human Services Environmental
Health Division

Project Referred To The Following Agencies:

Building Inspection Division, Public Works Land Use Division, Health and Human Services Environmental Health Division, County Counsel, CalFire, California Department of Fish And Wildlife, Northwest Information Center, Bear River Band Rohnerville Rancheria, Regional Water Quality Control Board, Humboldt County District Attorney, Humboldt County Agriculture Commissioner, Humboldt County Sheriff, Bridgeville Elementary School School District, Fortuna Union High School School District

Applicant Name Goddess Organics, LLC Key Parcel Number 208-113-008-000

Application (APPS#) 11590 Assigned Planner Cannabis Planner (CPOD) (707) 445-7541 Case Number(s) CUP16-295

Please review the above project and provide comments with any recommended conditions of approval. To help us log your response accurately, please include a copy of this form with your correspondence.

Questions concerning this project may be directed to the assigned planner for this project between 8:30am and 5:30pm Monday through Friday.

County Zoning Ordinance allows up to 15 calendar days for a response. If no response or extension request is received by the response date, processing will proceed as proposed.

☐ If this box is checked, please return large format maps with your response.

Return Response No Later Than Planning Commission Clerk
County of Humboldt Planning and Building Department
3015 H Street
Eureka, CA 95501
E-mail: PlanningClerk@co.humboldt.ca.us Fax: (707) 268-3792

We have reviewed the above application and recommend the following:

Conditional Approval

Comments:

DEH recommends conditional approval with the following conditions:

Development of the parcel must be brought into compliance with onsite wastewater disposal code and regulations. Within two years of permit approval, all plumbed structures must be served by permitted onsite wastewater treatment systems. All existing unpermitted onsite wastewater treatment systems, privies, or other non-compliant facilities must be destroyed and remediated under permit by DEH.

*This review and recommendation is for the Land Use aspects of the planning project and does not include or imply compliance with all DEH programs. Although DEH recommends the approval of the Planning project, Solid Waste and HazMat Program requirements need to be addressed directly with staff from those programs.

Response Date: 6/29/2018 Recommendation By: Benjamin Dolf