

ATTACHMENT 5

Referral Agency Comments and Recommendations

The project was referred to the following referral agencies for review and comment. Those agencies that provided written comments are checked off.

Referral Agency	Response	Recommendation	Location
Building Inspection Division	✓	Note	On file
Division Environmental Health	✓		Attached
Public Works, Land Use Division	✓	Conditional Approval	Attached
California Department of Fish & Wildlife		No response	
Northwest Information Center		No response	
Bear River Band Rancheria	✓	Further Study	On file and confidential
PG&E		No response	
Intertribal Sinkiyone Wilderness Council		No response	
Regional Water Quality Control Board		No response	
North Coast Unified Air Quality Management District		No response	
CalFire	✓	Note	On file
State Water Resources Control Board – Division of Water Rights		No response	
Mattole Unified School District		No response	
AG Commissioner		No response	
County Counsel		No response	
District Attorney		No response	
Sheriff	✓	Approval	On file
CA Division of Water Rights		No response	

ATTACHMENT 5A

DEH Referral Response

RE: Referral Responses for Cannabis Projects

Whittlesey, Joseph <jwhittlesey@co.humboldt.ca.us>

Wed 9/21/2022 9:07 AM

To: Holtermann, Michael <mholtermann@co.humboldt.ca.us>

Good morning Michael,

Thank you for the follow up email. Please find my referral comments for 15260 & 12042 below:

15260:

Processing activities must be supported by an approved onsite wastewater treatment system. Seasonal/outdoor cultivation sites may be supported by portable toilets. Applicant must obtain a permit for, and install, an approved onsite wastewater treatment system to support the processing location and either install approved septic systems or provide portable toilets to cultivation areas.

12042:

Seasonal cultivation without processing may use portable toilets to serve the operation. Permittee shall provide portable toilet(s) to cultivation areas, meeting appropriate setbacks per Humboldt County Code, or install a permitted onsite wastewater treatment system associated with a permitted structure.

Let me know if you have any other questions or concerns.

Best,

Joey Whittlesey

Senior Environmental Health Specialist

[Land Use Program](#)

[Division of Environmental Health](#)

100 H Street, Suite 100, Eureka, CA 95501

Phone: (707) 268-2240 – Fax: (707) 441-5699

ATTACHMENT 5B

Public Works Land Use Referral



DEPARTMENT OF PUBLIC WORKS
C O U N T Y O F H U M B O L D T

MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579
AREA CODE 707

ON-LINE
WEB: CO.HUMBOLDT.CA.US

PUBLIC WORKS BUILDING
SECOND & L ST., EUREKA
FAX 445-7409

ADMINISTRATION	445-7491	NATURAL RESOURCES	445-7741
BUSINESS	445-7652	NATURAL RESOURCES PLANNING	267-9540
ENGINEERING	445-7377	PARKS	445-7651
FACILITY MANAGEMENT	445-7493	ROADS	445-7421

CLARK COMPLEX
HARRIS & H ST., EUREKA
FAX 445-7388

LAND USE	445-7205
----------	----------

LAND USE DIVISION INTEROFFICE MEMORANDUM

TO: Michael Holtermann, Planner, Planning & Building Department

FROM: Kenneth M. Freed, Assistant Engineer

DATE: 10/14/2021

RE:	<table><tr><td>Applicant Name</td><td>CLOUD NINE RANCH LLC</td></tr><tr><td>APN</td><td>107-054-036</td></tr><tr><td>APPS#</td><td>PLN-2018-15260 SP</td></tr></table>	Applicant Name	CLOUD NINE RANCH LLC	APN	107-054-036	APPS#	PLN-2018-15260 SP
Applicant Name	CLOUD NINE RANCH LLC						
APN	107-054-036						
APPS#	PLN-2018-15260 SP						

The Department has reviewed the above project and has the following comments:

- ☒ The Department's recommended conditions of approval are attached as **Exhibit "A"**.
- ☐ Additional information identified on **Exhibit "B"** is required before the Department can review the project. **Please re-refer the project to the Department when all of the requested information has been provided.**
- ☐ Additional review is required by Planning & Building staff for the items on **Exhibit "C"**. **No re-refer is required.**
- ☐ *Road Evaluation Reports(s)* are required; See **Exhibit "D"**

Note: Prior to requesting an applicant to submit a road evaluation report, verify if the project is exempt from meeting road system performance standards under CCLUO v2.0 sections 313-55.4.6.5.1 and 314-55.4.6.5.1, even if this box is checked.

No re-refer is required.

*Note: Exhibits are attached as necessary.

Additional comments/notes:

Applicant has submitted a road evaluation report for the internal roads within the parcel, dated 04/27/21, with Part A –Box 2 checked, certifying that the road is equivalent to a road Category 4 standard. Mattole Road (County maintained) has a painted centerline stripe at this location.

Whether specifically addressed or not within the road evaluation report, per Section 1273.03 of State Fire Safe Regulations, California Code of Regulations (CCR), Title 14 Natural Resources, Division 1.5 Department of Forestry, Chapter 7 - Fire Protection, Subchapter 2 SRA Fire Safe Regulations, which have been established pursuant to California Public Resource Code Section 4290 et seq. (a) *At no point shall the grade for all roads and driveways exceed 16 percent;* (b) *The grade may exceed 16%, not to exceed 20%, with approval from the County of Humboldt Planning & Building Department with mitigations, such as paving, to provide for the same practical effect. Mitigation measures other than paving require an exception to be approved per Section 1270.06.* [Note: Fire Safe Regulations set forth in County Code Section 3111-1, et seq. have been superseded by the 01/01/2020 CCR since County Code has not been recertified by the Department of Forestry pursuant to Section 1270.04.]

// END //

Public Works Recommended Conditions of Approval

(All checked boxes apply) APPS # 15260

- ☒ COUNTY ROADS- PROXIMITY OF FARMS:
Applicant is advised that County maintained roads may generate dust and other impacts to farm(s). Applicant shall locate their farm(s) in areas not subject to these impacts. Applicant shall be responsible for protecting their farm(s) against these impacts. Applicant shall hold the County harmless from these impacts. Applicant is advised that a paved road may not always remain paved and Applicant shall locate their farms appropriately. Applicant is advised that the amount of traffic on a road will vary over time which may increase or decrease the impacts.
- ☒ COUNTY ROADS- FENCES & ENCROACHMENTS:
All fences and gates shall be relocated out of the County right of way. All gates shall be setback sufficiently from the County road so that vehicles will not block traffic when staging to open/close the gate. In addition, no materials shall be stored or placed in the County right of way.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.
- ☐ COUNTY ROADS- DRIVEWAY (PART 1):
The submitted site plan is unclear and/or shows improvements that are inconsistent with County Code and/or Department of Public Works policies. The applicant is advised that these discrepancies will be addressed at the time that the applicant applies to the Department of Public Works for an Encroachment Permit. If the applicant wishes to resolve these issues prior to approval of the Planning & Building permit for this project, the applicant should contact the Department to discuss how to modify the site plan for conformance with County Code and or Department of Public Works policies. Notes:
- ☒ COUNTY ROADS- DRIVEWAY (PART 2):
Any existing or proposed driveways that will serve as access for the proposed project that connect to a county maintained road shall be improved to current standards for a commercial driveway. Applicant must apply for and obtain an encroachment permit from the Department of Public Works prior to commencement of any work in the County maintained right of way. This also includes installing or replacing driveway culverts; minimum size is typically 18 inches.
 - If the County road has a paved surface at the location of the driveway, the driveway apron shall be paved for a minimum width of 18 feet and a length of 50 feet (or to break in slope) where it intersects the County road.
 - If the County road has a gravel surface at the location of the driveway, the driveway apron shall be rocked for a minimum width of 18 feet and a length of 50 feet where it intersects the County road.
 - If the County road is an urban road, frontage improvements (curb, gutter, and sidewalk) shall also be constructed to the satisfaction of the Department. Any existing curb, gutter or sidewalk that is damaged shall be replaced.
The exact location and quantity of driveways shall be approved by the Department at the time the applicant applies to the Department of Public Works for an Encroachment Permit.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.
- ☐ COUNTY ROADS- DRIVEWAY (PART 3):
The existing driveway will require substantial modification in order to comply with County Code. The applicant may wish to consider relocating the driveway apron if a more suitable location is available.
- ☐ COUNTY ROADS-PARKING LOT- STORM WATER RUNOFF:
Surfaced parking lots shall have an oil-water filtration system prior to discharge into any County maintained facility.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.
- ☒ COUNTY ROADS- DRIVEWAY & PRIVATE ROAD INTERSECTION VISIBILITY:
All driveways and private road intersections onto the County Road shall be maintained in accordance with County Code Section 341-1 (Sight Visibility Ordinance).

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.
- ☐ COUNTY ROADS- PRIVATE ROAD INTERSECTION: (AT COUNTY MAINTAINED RD)
Any existing or proposed non-county maintained access roads that will serve as access for the proposed project that connect to a county maintained road shall be improved to current standards for a commercial driveway. Applicant must apply for and obtain an encroachment permit from the Department of Public Works prior to commencement of any work in the County maintained right of way. This also includes installing or replacing intersection culverts; minimum size is typically 18 inches.
 - If the County road has a paved surface at the location of the access road, the access road shall be paved for a minimum width of 20 feet and a length of 50 feet (or break in slope) where it intersects the County road.
 - If the County road has a gravel surface at the location of the access road, the access road shall be rocked for a minimum width of 20 feet and a length of 50 feet where it intersects the County road.
This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.
- ☐ COUNTY ROADS- ROAD EVALUATION REPORT(S):
All recommendations in the Road Evaluation Report(s) for County maintained road(s) shall be constructed/implemented to the satisfaction of the Public Works Department prior to commencing operations, final sign-off for a building permit, or approval for a business license. An encroachment permit shall be issued by the Department of Public Works prior to commencement of any work in the County maintained right of way.

// END //