

Responding Agency: Humboldt County Department of Environmental Health

Response Date: 12/14/2018

Response: The site plan prepared by Green Roads Consulting shows the site septic system is installed within 100' of the Class II drainage. This septic system must be decommissioned and replaced under permit from DEH. Operator must install a new, permitted onsite wastewater treatment system (septic system) to serve the needs of the project.