

State of California
Well Completion Report
 Form DWR 188 Submitted 9/9/2020
 WCR2020-012636



Owner's Well Number _____ Date Work Began 09/03/2020 Date Work Ended _____
 Local Permit Agency Humboldt County Department of Health & Human Services - Land Use Program
 Secondary Permit Agency _____ Permit Number 18/19-1186 Permit Date 06/17/2019

Well Owner (must remain confidential pursuant to Water Code 13752)			Planned Use and Activity	
Name _____			Activity	<u>New Well</u>
Mailing Address _____			Planned Use	<u>Water Supply Irrigation - Agriculture</u>
City _____	State _____	Zip _____		

Well Location										
Address _____										
City	<u>Bridgeville</u>	Zip	<u>95526</u>	County	<u>Humboldt</u>	APN	<u>208-111-029</u>	Township	<u>01 N</u>	
Latitude	<u>40</u>	<u>28</u>	<u>28.7471</u>	N	Longitude	<u>-123</u>	<u>45</u>	<u>44.208</u>	W	
	Deg.	Min.	Sec.		Deg.	Min.	Sec.			
Dec. Lat.	<u>40.474652</u>			Dec. Long.	<u>-123.76228</u>				Range	<u>04 E</u>
Vertical Datum _____	Horizontal Datum		<u>WGS84</u>							
Location Accuracy _____	Location Determination Method		_____							
									Section	<u>07</u>
									Baseline Meridian	<u>Humboldt</u>
									Ground Surface Elevation	_____
									Elevation Accuracy	_____
									Elevation Determination Method	_____

Borehole Information				Water Level and Yield of Completed Well				
Orientation	<u>Vertical</u>	Specify _____		Depth to first water	<u>85</u>	(Feet below surface)		
Drilling Method	<u>Direct Rotary</u>	Drilling Fluid	<u>Air</u>	Depth to Static _____				
Total Depth of Boring	<u>240</u>	Feet		Water Level	<u>80</u>	(Feet)	Date Measured	<u>09/08/2020</u>
Total Depth of Completed Well	<u>240</u>	Feet		Estimated Yield*	<u>10</u>	(GPM)	Test Type	<u>Air Lift</u>
				Test Length	<u>4</u>	(Hours)	Total Drawdown	<u>180</u> (feet)
				*May not be representative of a well's long term yield.				

Geologic Log - Free Form		
Depth from Surface Feet to Feet	Description	
0	5	top soil
5	38	soft shale
38	58	hard shale
58	163	hard shale blue sandstone mix
163	215	hard shale
215	240	soft shale

RECEIVED

SEP 09 2020

HUMBOLDT CO. DIVISION
 OF ENVIRONMENTAL HEALTH

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specifications	Wall Thickness (Inches)	Outside Diameter (Inches)	Screen Type	Slot Size If any (Inches)	Description
1	0	60	Blank	PVC	OD: 5.563 In. SDR: 21 Thickness: 0.265 In.	0.265	5.563			
1	60	240	Screen	PVC	OD: 5.563 In. SDR: 21 Thickness: 0.265 In.	0.265	5.563	Milled Slots	0.032	

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	20	Bentonite	Other Bentonite		Sanitary Seal
20	240	Filter Pack	Other Gravel Pack	3/8 inch	Pea Gravel

Other Observations:

Borehole Specifications		
Depth from Surface Feet to Feet	Borehole Diameter (Inches)	
0	240	10

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	FISCH DRILLING		
	Person, Firm or Corporation		
3160 JOHNSON ROAD	HYDESVILLE	CA	95547
Address	City	State	Zip
Signed	<i>electronic signature received</i>	09/09/2020	683865
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

Attachments
scan.pdf - Location Map

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number
		N	W
Latitude Deg/Min/Sec		Longitude Deg/Min/Sec	
TRS:			
APN:			