

**Exhibit 1B**

**Public Works Department Recommended Conditions of Approval**

## EXHIBIT A



### DEPARTMENT OF PUBLIC WORKS

## C O U N T Y O F H U M B O L D T

MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579  
AREA CODE 707

ON-LINE  
WEB: CO.HUMBOLDT.CA.US

	PUBLIC WORKS BUILDING SECOND & L ST., EUREKA FAX 445-7409			CLARK COMPLEX HARRIS & H ST., EUREKA FAX 445-7388	LAND USE
ADMINISTRATION	445-7491	NATURAL RESOURCES		445-7741	
BUSINESS	445-7652	NATURAL RESOURCES PLANNING		267-9540	
ENGINEERING	445-7377	PARKS		445-7651	
FACILITY MANAGEMENT	445-7493	ROADS		445-7421	

### LAND USE DIVISION INTEROFFICE MEMORANDUM

TO: Steve Lazar, Senior Planner

FROM: Robert W. Bronkall, Deputy Director *RB*

RE: SUBDIVISION REQUIREMENTS - IN THE MATTER OF THE APPLICATION FENNELL, APPLICATION #PLN-2022-17900 PMS-CDP, APN 400-141-012, FOR APPROVAL OF A TENTATIVE MAP, CONSISTING OF 0.38 ACRES INTO 2 PARCELS

DATE: 11/28/2022

-----

*The following requirements and standards are applicable to this project and must be completed to the specifications and satisfaction of the Department of Public Works (Department) before the subdivision map may be filed with the County Recorder. If there has been a substantial change in the project since the last date shown above, an amended report must be obtained and used in lieu of this report. Prior to commencing the improvements indicated below, please contact the Subdivision Inspector at 445-7205 to schedule a pre-construction conference.*

These recommendations are based on the tentative map prepared by Kelly-O'Hern dated August 2022 and dated as received by the Humboldt County Planning Division on August 24, 2022.

NOTE: All correspondence (letters, memos, faxes, construction drawings, reports, studies, etc.) with this Department must include the Assessor Parcel Number (APN) shown above.

**READ THE ENTIRE REPORT BEFORE COMMENCING WORK ON THE PROJECT**

### 1.0 MAPPING

**1.1 EXPIRATION OF TENTATIVE MAP:** Applicant is advised to contact the Planning & Building Department to determine the expiration date of the tentative map and what time extension(s), if any, are applicable to the project. Applicant is responsible for the timely filing of time extension requests to the Planning & Building Department.

Applicant is responsible for completing all of the subdivision requirements prior to expiration of the tentative map. Applicant is advised to promptly address all of the subdivision requirements in order to avoid the tentative map expiring prior to completion of the subdivision requirements. Applicants are encouraged to contact a land development professional for advice on developing a realistic schedule for the processing of the project.

**1.2 MAP TYPE:** Applicant must cause to be filed a subdivision map showing monumentation of all property corners to the satisfaction of this Department in compliance with Humboldt County Code Section 326-31. Subdivision map checking fees shall be paid in full at the time the subdivision map is submitted for checking. County Recorder fees shall be paid prior to submittal of the map to the County Recorder for filing. The subdivision map must be prepared by a Land Surveyor licensed by the State of California -or- by a Civil Engineer registered by the State of California who is authorized to practice land surveying.

All Department charges associated with this project must be paid in full prior to the subdivision map being submitted to the County Recorder for filing.

Applicant shall submit to this Department a “.pdf” scan of the subdivision map as filed by the County Recorder. [Reference: Government Code Section 66466(f)]

Prior to submitting the subdivision map to the County Surveyor for map check, applicant shall submit the subdivision map to the utility providers to provide input on necessary public utility easements. Copies of the responses from the utility providers shall be included with the first submittal of the subdivision map to the County Surveyor.

**1.3 DEPOSIT:** Applicant shall be required to place a security deposit with this Department for inspection and administration fees as per Humboldt County Code Section 326-13 prior to review of the improvement plans, review of the subdivision map, or the construction of improvements, whichever occurs first.

**1.4 EASEMENTS:** All easements that encumber or are appurtenant to the subdivision shall be shown graphically on the subdivision map. Those easements that do not have a metes and bounds description shall be noted on the subdivision map and shown as to their approximate location.

**1.5 FURTHER SUBDIVISION:** At least some of the parcels may be further divided; therefore, the applicant shall conform to Humboldt County Code Section 323-6(a)(5), Statements to Accompany a Tentative Subdivision Map.

**1.6 PRIVATE ROADS:** Pursuant to County Code Section 324-2(c)(3), the subdivision map shall show the lanes clearly labeled "Non-County Maintained Lane" or "Non-County Maintained Road". Pursuant to County Code Section 324-2(c)(5), the following note shall appear on the map or instrument of waiver, which shall read substantially as follows:

"If the private lane or lanes shown on this plan of subdivision, or any part thereof, are to be accepted by the County for the benefit of the lot owners on such lane rather than the benefits of the County generally, such private lane or lanes or parts thereof shall first be improved at the sole cost of the affected lot owner or owners, so as to comply with the specification as contained in the then applicable subdivision regulations relating to public streets."

**1.7 DEDICATIONS:** The following shall be dedicated on the subdivision map, or other document as approved by this Department:

**(a) PUBLIC ROAD: PENISULA DRIVE (#3K905)**

*Public Road:* Applicant shall cause to be dedicated on the subdivision map to the County of Humboldt an easement for public road purposes lying within 25 feet of the center line of the County road. The applicant is only responsible to cause to be dedicated lands that are included within the boundary of the proposed subdivision.

*PUE:* Applicant shall cause to be dedicated to the County of Humboldt on the subdivision map a 10 foot wide public utility easement (PUE) adjacent to the right of way for the road or as otherwise approved by this Department. Additional PUEs shall be dedicated in a manner, width, and location approved by this Department.

**(b) PRIVATE ROADS: TAYLOR COURT & UNNAMED ACCESS ROAD**

*PUE:* Applicant shall cause to be dedicated to the County of Humboldt on the subdivision map a 10 foot wide public utility easement (PUE) adjacent to the right of way for the road or as otherwise approved by this Department. Additional PUEs shall be dedicated in a manner, width, and location approved by this Department.

The applicant shall cause to be dedicated to the County of Humboldt a PUE over the entire area of the access easement for the road.

**(c) NEIGHBORHOOD BOX UNIT (NBU) MAILBOXES:** Prior to submittal of the subdivision map, provide a sign-off from the Post Office on the location of the neighborhood box unit. Applicant shall cause to be dedicated on the subdivision map additional sidewalk easements as necessary to accommodate the NBU.

Note: The Post Office may not require a NBU for this project.

**1.8 LINES OF OCCUPATION:** Applicant shall provide prospective buyers with notice of any fences that are not on the property lines.

**2.0 IMPROVEMENTS**

**2.1 CONSTRUCTION PLANS:** Pursuant to County Code §326-3, construction plans shall be submitted for any required road, drainage, landscaping, and pedestrian improvements. Construction plans must be prepared by a Civil Engineer registered by the State of California. Construction plans shall be on a sheet size of 22" x 34", unless approved otherwise by this Department. Construction of the improvements shall not commence until authorized by this Department. This Department will require the submittal of 1 full size (22" x 34") set and 1 reduced (11" x 17") set of the approved construction plans prior to start of work. (See County code Section 326-3)

The construction plans shall show the location of all proposed new utilities and any existing utilities within 10 feet of the improvements. The plans shall be signed as approved by the local fire response agency and public utility companies having any facilities within the subdivision prior to construction authorization by this Department.

Construction plans shall be tied into elevation datum approved by this Department.

Unless otherwise waived by this Department, record drawing ("As-Built") plans shall be submitted for any road, drainage, landscaping, and pedestrian improvements that are constructed as part of this project. Record drawing plans must be prepared by a Civil Engineer registered by the State of California. Once approved by this Department, one (1) set of "wet stamped" record drawings on 22" x 34" mylar sheets shall be filed with this Department.

**2.2 CONSTRUCTION PERIOD:** Construction of improvements for this project will not be allowed to occur between October 15 and April 15 without permission of this Department.

**2.3 TRAFFIC CONTROL DEVICES & SIGNS:** Traffic control devices and signs may need to be placed as required and approved by this Department. All signs and striping on County maintained roads shall be installed by the County at the expense of the developer, unless otherwise approved by the Department.

- (a) A stop sign shall be installed on Taylor Court and the Unnamed Access Road at its intersection with Peninsula Drive. When the road is paved, a "stop" pavement marking and limit line shall be installed.
- (b) Pursuant to County Code Section 324-2(c)(4), non-county maintained roads shall be posted with a sign of at least 2 square feet in size containing substantially the following words in 2" high black letters on a yellow background: "Not a County Maintained Road" or "Not a County Maintained Street". The sign shall be approved by the Department prior to installation. (last paragraph for private roads)
- (c) Street name signs shall be provided at all road intersections.
- (d) Fire hydrants shall be identified with a retroreflective blue colored raised pavement marker.
- (e) Additional signing and striping may be required by the Department upon review of the improvement plans. This includes, but is not limited to, centerline striping, two way left turn lane striping, bicycle lane striping, edge lines, dead end road signs, no outlet signs, speed limit signs, warning signs, etc....

**2.4 ACCESS ROADS:** The access road(s) serving the subdivision shall be constructed to the satisfaction of this Department as follows:

- (a) Fronting the subject parcel **Peninsula Drive** shall be widened to have two 12 foot wide paved travel lanes and an 8 foot wide paved parking lane on the east side, the remainder of the right of way shall be gravel.
- (b) The intersection of the subdivision access road(s) and the County road shall be constructed in conformance with the standards for a private road intersection as illustrated in Caltrans standards. The access openings must conform to Humboldt County Code Section 341 regarding visibility. **Portions of existing fences withing the County right of way and not in compliance with county code shall be relocated, removed, or modified for compliance with County Code.**

- (c) **Taylor Court and Unnamed Access Road** shall be paved for a minimum length of 50 feet from the edge of the County road.
- (d) Applicant shall be required to construct a parking lane along the frontage of the subdivision on in a manner satisfactory to this Department.
- (e) Nothing is intended to prevent the applicant from constructing the improvements to a greater standard.
- (f) Nothing is intended to prevent this Department from approving alternate typical sections, structural sections, drainage systems, and road geometrics based upon sound engineering principals as contained in, but not limited to, the Humboldt County Roadway Design Manual, Caltrans Highway Design Manual, Caltrans Local Programs Manual, Caltrans Traffic Manual, California Manual on Uniform Traffic Control Devices (MUTCD), and AASHTO's A Policy of Geometric Design of Highways and Streets (AKA "The Green Book"). Engineering must not be in conflict with Humboldt County Code or County adopted guidelines and policies.
- (g) Applicant shall remove and replace any public curb, gutter, sidewalk, flowline drain, or pavement found by this Department to be broken, uplifted, or damaged that fronts or is within the subdivision.
- (h) All road intersections shall conform to Humboldt County Code Section 341 regarding visibility.
- (i) The surface of the access road(s) shall conform to the *Structural Section* requirements within this document.

**2.5 STRUCTURAL SECTION:** The access road(s) shall be constructed to a structural section recommended in the soils report and as approved by this Department.

- (a) **For paved road surfaces**, the structural section shall include a minimum of 0.2 feet of Caltrans Type A 1/2" hot mix ("asphalt") over 0.67 foot of Caltrans Class 2 aggregate base. If required by this Department, the structural section of all roads shall be determined by Caltrans R-Value method using a Traffic Index (T.I.) approved by this Department. Based upon soil conditions, this Department may also require a geotextile fabric to be placed on top of the sub grade.
- (b) When widening hot mix ("asphalt") roads, the widened road shall be paved with hot mix. A sawcut is required to ensure a uniform joint between the existing and new pavements. The location of the sawcut shall be approved by this Department based upon the condition of the existing road surface.

Access roads and driveways may include decorative accent treatments such as, but not limited to, stamped concrete or decorative brick pavers. Decorative accent treatments must provide appropriate traction for pedestrians, bicycles, and vehicles. **Decorative access treatments are not permitted within the public right of way**, unless approved in writing by this Department.

- (c) **For unpaved road surfaces**, the structural section shall include a minimum, of 0.5 foot of Caltrans Class 2 aggregate base. Paved surfaces are required for grades in excess of 16%.
- 2.6 UNKNOWN IMPROVEMENTS:** Other on-site and/or off-site improvements may be required which cannot be determined from the tentative map and/or preliminary improvement plans at this time. These improvements will be determined after more complete improvement plans and profiles have been submitted to the County for review.
- 2.7 UTILITIES:** The proposed improvements may require the undergrounding or relocation of existing facilities at the expense of the applicant. Undergrounding of existing facilities, relocation of existing facilities, or construction of new facilities shall be completed prior to constructing the structural section for the roadway.

If any utilities are required to be installed as a condition of tentative map, the utility work shall be completed prior to constructing the structural section for the road. All laterals shall be extended onto each lot and marked in a manner that they will be easily located at the time of individual hookups. A letter of completion of all work from each involved utility company shall be submitted prior to constructing the roadway structural section. Any utilities that need to be relocated shall be done solely at the subdivider's expense.

Applicant shall remove any abandoned utilities (natural gas, electrical, cable tv, etc.) within the public right of way fronting the subdivision or within the subdivision as directed by this Department.
- 2.8 PERMITS:** Pursuant to County Code §411-11 (a)&(b), an encroachment permit is required to be obtained prior to construction from this Department for all work within the right of way of a County maintained road.
- 2.9 NEIGHBORHOOD BOX UNIT (NBU) MAILBOXES:** When clustered mailboxes (neighborhood box units) are required by the Post Office, applicant shall obtain approval for the location of the mailbox unit from the Post Master. The pad for the mailbox unit shall be constructed as part of the subdivision and shall be encompassed by a sidewalk easement or other easement, as approved by this Department. If the NBUs will not be installed by the Post Office, the subdivider shall install the NBUs as part of the subdivision.

Note: The Post Office may not require an NBU for this project.
- 2.10 GATES:** Gates are not permitted on County right of way for public roads without authorization of the Board of Supervisors. Gates must not create a traffic hazard and must provide an appropriate turnaround in front of the gate. Existing gates shall be evaluated for conformance.
- 2.11 COMPLETION OF IMPROVEMENTS ON PARCEL MAP SUBDIVISION:** When improvements are not constructed before the subdivision map is filed with the County Recorder, the following apply:
- 2.12** Pursuant to Government Code section 66411.1 (improvement timing), fulfillment of reasonable on-site and off-site construction requirements may be imposed prior to Parcel Map filing with the County Recorder if found necessary for the public health or safety or orderly

development of the area. The following improvements are necessary for the public health or safety or orderly development of the area and shall be completed: (1) within twenty-four (24) months after the filing date of the Parcel Map, or (2) prior to issuance of a building permit on any property subject to this notice, or (3) prior to any other grant of approval for any property subject to this notice, whichever occurs first:

- All improvements specified in Item 2.4.

**2.13** The following improvements shall be completed: (1) prior to issuance of a building permit on any property subject to this notice, or (2) prior to any other grant of approval for any property subject to this notice, whichever occurs first:

<NONE>

**2.14** The following improvements shall be completed: (1) within twenty-four (24) months after the issuance of a Building Permit on any property subject to this notice, or (2) prior to issuance of an Occupancy Permit for any property subject to this notice, whichever occurs first:

<NONE>

**2.15** The following note shall be placed on the development plan:

"This subdivision was approved with requirements to construct improvements. At the time the parcel map was filed, the improvements were not completed. The subdivision improvements must be completed within the timelines specified in the *Notice of Construction Requirements*. Building permits or other development permits cannot be obtained until the required improvements are constructed to the satisfaction of the County. The improvements required in the *Notice of Construction Requirements* are shown on the improvement plans prepared by \_\_\_\_\_, dated \_\_\_\_\_, and are signed as approved by the County on \_\_\_\_\_. Contact the Land Use Division of the Department of Public Works for details."

The Department shall cause to be recorded at the time of filing of the parcel map with the County Recorder a *Notice of Construction Requirements*.

### **3.0 DRAINAGE**

**3.1 DRAINAGE ISSUES:** Applicant shall be responsible to correct any involved drainage problems associated with the subdivision to the satisfaction of this Department.

**3.2 DRAINAGE REPORT:** Applicant must submit a complete hydraulic report and drainage plan regarding the subdivision for review and approval by this Department. The report and plan must be prepared by a Civil Engineer registered by the State of California. This may require the construction of drainage facilities on-site and/or off-site in a manner and location approved by this Department.

**3.3 LOW IMPACT DEVELOPMENT (LID):** The subdivision is required to comply with County Code Section 337-13. The applicant shall submit a Storm Water Information Sheet for review and approval by the County. The improvement plans must incorporate LID strategies for the entire subdivision, including roads, lots, and other areas.

At the time that the subdivision improvements are constructed, the LID elements related to an individual lot may be deferred until such time as the lot is developed. It is intended that any deferred LID strategies shown on the improvement plans for a lot are conceptual in nature and subject to adjustment/refinement at the time that the building permit is applied for. Any deferred LID improvements must be shown and identified on the Development Plan.

When there will be deferred LID improvements, a separate sheet in the improvement plans shall be provided for the LID concepts proposed for the individual lots. It is intended that this sheet will be attached to the development plan to facilitate issuance of a building permit at a later time.

#### **4.0 GRADING**

<NONE>

#### **5.0 MAINTENANCE**

**5.1 MAINTENANCE OF IMPROVEMENTS:** The improvements to be constructed as part of this subdivision will not be maintained by the County. Pursuant to Humboldt County Code Section 324-2 (b) regarding Private Lanes, the Applicant must provide a permanent maintenance plan acceptable to this Department for all improvements including, but not limited to, the following: roads, drainage systems (pipes, drainage inlets, detention basins), pedestrian facilities, and landscape areas. An engineer's estimate for the cost of yearly maintenance must be approved by this Department. Maintenance shall be provided by a maintenance association, district, or other means as approved by this Department. More than one maintenance plan may be required.

Based upon the tentative map, it appears that the following will need to be maintained by a maintenance plan. A maintenance plan for the non-county maintained roads known as

- Taylor Court
- Unnamed Access Road.

If a maintenance association currently exists for the access road, applicant shall attempt to the satisfaction of this Department to annex the subdivision into the existing road maintenance association. That portion of this condition regarding road maintenance may be waived if the applicant provides evidence satisfactory to this Department that the subject property already belongs to a maintenance association for the access road(s).

A maintenance plan is not required for driveways; as driveways serve only one parcel. A maintenance plan is *optional* for roads that serve only two parcels. A maintenance plan is required for roads serving three or more parcels.

#### **6.0 DEVELOPMENT PLAN**

<NONE>

#### **7.0 LANDSCAPING**

<NONE>

// END //

## EXHIBIT A



### DEPARTMENT OF PUBLIC WORKS C O U N T Y O F H U M B O L D T

MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579  
AREA CODE 707

ON-LINE  
WEB: CO.HUMBOLDT.CA.US

	PUBLIC WORKS BUILDING SECOND & L ST., EUREKA FAX 445-7409		CLARK COMPLEX HARRIS & H ST., EUREKA FAX 445-7388
	ADMINISTRATION 445-7491 BUSINESS 445-7652 ENGINEERING 445-7377 FACILITY MANAGEMENT 445-7493	NATURAL RESOURCES 445-7741 NATURAL RESOURCES PLANNING 267-9540 PARKS 445-7651 ROADS 445-7421	LAND USE 445-7205

---

### LAND USE DIVISION INTEROFFICE MEMORANDUM

---

TO: Steve Lazar, Senior Planner

FROM: Robert W. Bronkall, Deputy Director *RF*

DATE: 11/28/2022

RE: FENNELL, APN 400-141-012, PLN-2022-17900 PMS CDP

**PRELIMINARY SUBDIVISION REPORT:** A *preliminary report* was submitted in lieu of a *preliminary subdivision report* as specified in County Code Section 323-6(c).

**LOW IMPACT DEVELOPMENT (LID):** While the subject property is located within the municipal separate storm sewer system (MS4) boundary area, the subdivision itself does not require LID standards to be applied due to less than 2,500 SF of impervious area being created.

**UNNAMED ACCESS ROAD:** The Department recommends that the Planning & Building Department determine if the unnamed access road is to be named prior to the project being presented to the Planning Commission for approval.

**NON-COUNTY MAINTAINED ROAD NOTE:** The project will be taking access from an existing non-county maintained road. If a road maintenance association currently exists, this Department recommends that the applicant secure an agreement for annexation prior to the project being presented to the Planning Commission. If an agreement for annexation cannot be reached, then the issue of road maintenance should be discussed/addressed at the Planning Commission meeting.